

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0067:164

Page 1 of 1

CATEGORY: Fire Alarm Devices for The Hearing Impaired

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Models MT-15/75S; MTS-15, MTS-15/75, MTS-30, MTS-75; MTS4-15, MTS4-15/75, MTS4-30 and MTS4-75 multitone strobe horns. Numerical suffixes designate minimum candela. All models rated at 60 flashes/minute. Model MT-15/75S is a synchronized strobe and must be use with Model SCM-24 sync control module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-31 VDC/FWR

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical/candela rating and UL label.

APPROVAL: Listed as signaling devices for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. For indoor use only. Models MT-15/75S, MTS-15/75 and MTS4-15/75 are intended for wall mount installation only. All other models are intended for ceiling/wall mount installation.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7125-0785:122

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

OCTOBER 26, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager